

# 2021 Annual Drinking Water Quality Report Consumer Confidence Report (CCR)

East Bell Water Supply Corporation  
254-985-2611  
PWS ID# 0140118

Annual Drinking Water Quality Report for the Period of January 1 to December 31, 2021.

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

You can attend regular scheduled public meetings. Meeting times and dates are posted at the East Bell Water office, located at 16490 State Highway 53 Temple TX 76501 and on the website at [www.eastbellwater.com](http://www.eastbellwater.com). For more information regarding this report contact: Cheryl Walden at 254-985-2611 or Distribution Supervisor Randy Frei, Frei Enterprises, 254-985-2243.

"Este reporte incluye informacion importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (254) 985-2611."

## **East Bell Water Supply Corporation Board of Directors:**

Marvin Green	President
Eugene Brenek	Vice-President
Abbey Zavodny	Secretary-Treasurer
Donald Malovets	Director
Mike Harper	Director

## **Source of Drinking Water**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### **Information about Source Water Assessments**

The source of drinking water used by East Bell WSC is purchased surface water from Central Texas Water Supply Corporation (TX0140161); which is processed from Stillhouse Hollow Lake Reservoir and ground water pumped from wells in the Trinity Aquifer located in Bell County. The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact the East Bell Water office at 254-985-2611.

**2021 Water Quality Test Results  
EAST BELL WATER SUPPLY CORPORATION**

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
<b>*Haloacetic Acids (HAA5)</b>	2021	20	10.2 – 25.1	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
<b>*Total Trihalomethanes (TTHM)</b>	2021	32	10 - 43	No goal for the total	80	ppb	N	By-product of drinking water disinfection.

\* The value in the Highest Level Detected column is the highest average of all HAA5 and TTHM sample results collected at a location over a year.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
<b>Barium</b>	01/22/2019	0.041	0.0396 – 0.041	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
<b>Cyanide</b>	02/12/2020	40	0 - 40	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.
<b>Fluoride</b>	02/12/2020	0.35	0.35 – 0.35	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
<b>Nitrate [measured as Nitrogen]</b>	2021	0.15	0.09 – 0.15	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
<b>Combined Radium 226/228</b>	2021	1.5	1.5 - 1.5	0	5	pCi/L	N	Erosion of natural deposits.

Volatile Organic Contaminants	Collection Date	Highest Level Detected	Range Of Individual Samples	MCLG	MCL	Units	Violation	Likely Source Of Contamination
Xylenes	2021	0.0005	0 – 0.0005	10	10	ppm	N	Discharge from petroleum factories; discharge from chemical factories.

**Lead and Copper**

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
<b>Copper</b>	2021	1.3	1.3	0.21	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
<b>Lead</b>	2021	0	15	1.1	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

## Disinfection Data

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Violation	Source of Chemical
2021	Chloramines	1.1	0.63	3.20	4	<4.0	ppm	N	Water additive used to control microbes

There were no violations for East Bell Water Supply Corporation for the year 2021.

## 2021 Water Quality Test Results CENTRAL TEXAS WATER SUPPLY CORPORATION

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
<b>Chlorite</b>	2021	0.254	0 - 0.254	0.8	1	ppm	N	By-product of drinking water disinfection
<b>*Haloacetic Acids (HAA5)</b>	2021	18	11.4 – 25	No goal for the total	60	ppb	N	By-product of drinking water disinfection
<b>*Total Trihalomethanes (TTHM)</b>	2021	29	19.9 – 41.2	No goal for the total	80	ppb	N	By-product of drinking water disinfection

\* The value in the Highest Level Detected column is the highest average of all HAA5 and TTHM sample results collected at a location over a year.

Inorganic contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
<b>Barium</b>	2021	0.0466	0.0294 – 0.0466	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
<b>Cyanide</b>	2021	100	60 - 100	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.
<b>Fluoride</b>	2021	0.7	0.21 – 0.67	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
<b>Nitrate (measured as Nitrogen)</b>	2021	0.16	0.1 – 0.16	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Like source of contamination
<b>Atrazine</b>	2021	0.21	0 – 0.21	3	3	ppb	N	Runoff from herbicide use on row crops

## Turbidity

	Level Detected	Limit (Treatment Technique)	Violation	Likely Source of Contamination
Highest Single Measurement	1 NTU	1 NTU	N	Soil runoff.
Lowest monthly % meeting limit	74%	0.3 NTU	Y	Soil runoff.

### Information Statement:

Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

### Total Organic Carbon:

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violation section.

## Central Texas Water Supply Corporation Violations

Interim Enhanced SWTR			
The Interim Enhanced Surface Water Treatment Rule improves control of microbial contaminants, particularly Cryptosporidium, in systems using surface water, or ground water under the direct influence of surface water. The rule builds upon the treatment technique requirements of the Surface Water Treatment Rule.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONTHLY COMB FLTR EFFLUENT (IESWTR/LT1)	02/01/2021	02/28/2021	Turbidity levels, though relatively low, exceeded a standard for the month indicated. Turbidity (cloudiness) levels are used to measure effective filtration of drinking water.

Public Notification Rule			
The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency).			
Violation Type	Violation Begin	Violation End	Violation Explanation
PUBLIC NOTICE RULE LINKED TO VIOLATION	05/12/2015	02/24/2021	We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.

<b>DEFINITIONS &amp; ABBREVIATIONS</b>	The following tables contain scientific terms and measures, some of which may require explanation.
Action Level:	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Action Level Goal (ALG):	The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine ( if possible ) why total coliform bacteria has been found in our water system.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine ( if possible ) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level Or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal Or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum Residual Disinfectant Level Or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL:	Million fibers per liter (a measure of asbestos)
mrem:	Millirems per year (a measure of radiation absorbed by the body )
na:	Not applicable.
NTU:	Nephelometric turbidity units (a measure of turbidity)
pCi/L:	Picocuries per liter (a measure of radioactivity)
ppb:	Micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	Milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppq:	Parts per quadrillion, or picograms per liter (pg/L)
ppt:	Parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

*East Bell Water Supply Corporation is an equal opportunity provider and employer.*